



VIDHARBHA KONKAN GRAMIN BANK

Govt. of India, Bank of India & Govt. of Maharashtra Undertaking

Regional Office, Akola.

VKGB/RO/AKOLA/A&S/ 2018/

Date:04/06/2018

To,
M/s _____

Tender No.
AR0/2018/4

Re: Inviting tender for Electrification & Data Cabling work of Malkapur (Akl) Branch

Sealed tenders are inviting for Electrification & Data Cabling work of our Malkapur (Akl) Branch on the terms and conditions given in enclosed tender notice. Being an empanelled Contractor on panel of Bank or other Nationalised Bank panel for Electrification and Data Cabling. We request you to submit your quotation on schedule date and time positively.

The Electrification & Data Cabling drawing, measurement, list of approved material and general conditions for quotations are enclosed with this letter.


(R.R. Khade)
Regional Manager

Encl:

- 1) Tender Notice for Electrification & Data Cabling work
- 2) Plan Layout
- 3) List of Approved Makes for Electrification & Data Cabling Work
- 4) Tender Form

E:\RO\KHEDKAR\A&S\LANJIT\Premises\Malkapur (Akl)\Malkapur Akl_Estimate\Electrification & Data Cabling Malkapur Akl.doc

Regional Office:- "Madhumalati Building" 1st Floor, Gupte Marg, Jatharpeth, Akola. PIN: 444005

Phone No:- (0724-2491766, 2490100, Email:- ykgb.robul@gmail.com



VIDHARBHA KONKAN GRAMIN BANK

Govt. of India, Bank of India & Govt. of Maharashtra Undertaking

Regional Office, Akola.

Enclosure to the Letter Ref No. VKGB/RO/AKOLA/A&S/2018/ dated 04/06/2018

Tender Notice For Electrification & Data Cabling Work of Malkapur Akl Branch.

1. Vidharbha Konkan Gramin Bank, Regional Office, Akola are inviting sealed tender for Electrification & Data Cabling Work of Malkapur Akl Branch Dist- Akola. Sealed tenders should be address to 'The Regional Manager, Vidharbha Konkan Gramin Bank, Regional Office, Madhumalti Building, Gupte Marg, Jatharpeth Akola -444005' Contact No. 0724-2490100, 2490533

2. Tender should super-scribed "TENDER FOR Electrification & Data Cabling For Malkapur (Akl)" and should reach to us on or before 18/06/2013 not later than 4.00 p.m. No tender will be accepted after given date and time.

3. Only those contractors/firms who are on the panel of the Bank or other Nationalized Bank are eligible to participate in this tender.

4. Following documents are require to be submit with tender

- Registration certificate of the firm/company.
- Copy of Audited statement of current financial year 2017-18.
- PAN Card
- Full details of the Bank Account.

Tenders received without above stated documents are not considered for the process.

5. General conditions for Quotation.

- The design patterns / drawing indicated in the tender document are tentative only and it can be changed as per requirement and instructions of the Architect / Bank authority.
- The work allotted should be completed in stipulated period of 3 weeks from written order. The delay in completing the work beyond the given period will be charged penalty @ Rs.200/- per day for delayed period.

E:\RO\KHEDKAR\A&S\RANJIT\Premises\Malkapur (Akl)\Malkapur Akl_Estimate\Electrification & Data Cabling Malkapur Akl.doc

Regional Office:- "Madhumalati Building" 1st Floor, Gupte Marg, Jatharpeth, Akola. PIN: 444005

Phone No:- (0724-2491766, 2490100, Email:- vkgb.robul@gmail.com



VIDHARBHA KONKAN GRAMIN BANK

Govt. of India, Bank of India & Govt. of Maharashtra Undertaking

Regional Office, Akola.

Enclosure to the Letter Ref No. VKGB/RO/AKOLA/A&S/2018/ dated 04/06/2018

- 3) Contractor should not object for any deduction in the items of said work or quality of item and cost will be reduced accordingly.
- 4) In case of changes in specification with the permission of authority, cost will be calculated accordingly.
- 5) The contractor should quote the rate in figures as well as in words for the work as running feet and also total estimate.
- 6) The rates quoted by the contractor should include all the material, all leads and lifts, scaffoldings, labour, equipments etc. so also **all taxes including GST**, VAT, sales tax, octroi, transportation etc needed for the job.
- 7) All erasures and alterations/corrections made while filling the quotation must be authenticated by the signature of contractor. Overwriting of the figures is not permitted; otherwise the quotation may be liable for rejection.
- 8) The contractor shall remove all debris, malaba etc. wash and clean the floor and handover the site in proper manner after completion of the work on due date.
- 9) The work executed should be approved by the bank and contractor shall rectify any bad workmanship pointed out at any stage and remove from site all the rejected material immediately.
- 10) The contractor should inform the bank or its representative / panel architect to check measurement of any work / material which is likely to be hidden before covering.
- 11) The contractor will not execute any extra item without Bank's permission in writing.
- 12) Conditional quotation quoted by the renderer is liable to be rejected.
- 13) The quotation will remain valid for the period of 3 months from the date of opening of the tenders. Bank reserves the right to accept or reject any or all quotations without assigning reason to do so.
- 14) All pages of the tender documents, conditions, specifications, schedules etc, shall be initialed and signed by the contractor before submission of quotations as a token of acceptance.
- 15) The contractor shall make his own arrangement for watch and ward of his materials and shall ensure the safety, breakage and theft of material fixed or unfixed by him or other materials immediately. Bank will not be responsible for any theft, loss or damage etc.
- 16) Drinking water & electricity will be provided by Bank to the contractor.
- 17) Child labour should not be engaged by contractor.

E:\RO\KHEDKAR\A&S\RANJIT\Premises\Malkapur (Akl)\Malkapur Akl_Estimate\Electrification & Data Cabling Malkapur Akl.doc

Regional Office:- "Madhumalati Building" 1st Floor, Gupte Marg, Jatharpeth, Akola. PIN: 444005

Phone No:- (0724-2491766, 2490100, Email:- vkgb.robul@gmail.com



VIDHARBHA KONKARN GRAMIN BANK

Govt. of India, Bank of India & Govt. of Maharashtra Undertaking

Regional Office, Akola.

- 18) The contractor will take necessary precautions for carrying out work avoiding any damage to structures / decorative parts of the property. The contractor will rectify any damages done at his own costs.

Enclosure to the Letter Ref No. VKGB/RO/AKOLA/A&S/2018/ dated 04/06/2018

- 19) The bank has a right to alter the nature of work and to add or omit any items of work or to have option of the same carried out departmentally or otherwise and such alterations or variations shall be carried out without prejudice to this contract.
- 20) The bank has right to terminate the contract, if the contractor abandons the work, or fails to commence and complete the work in time, or fails to abide by the contract conditions.

6. Other Conditions for Quotation.

- 1) All the work shall be carried out as per detail and specifications or as directed by the consultant. Prior approval from consultant / bank shall be obtained for any change / deviation from the original plan.
- 2) Payment of bill shall be made upon verification and recommendation from Architect/Consultant / Branch Manager.
- 3) Bank shall retain 10% of the total value of the contract as retention money and the same will be refunded after one year after the date of settlement of original bill, provided that there is no defect or all defects are removed. Likewise Bank will deduct applicable TDS etc at the time of final payment.
- 4) All disputes and differences of any kind whatsoever arising out of or in connection with the contract or carrying out of the work (whether during the progress of the work or after its completion and whether before or after determination, abandonment or breach of the contract) shall be referred to and settled by the Bank's Chairman, Head Office Nagpur.
- 5) The decision of the consultant shall be final in case of any technical clarification.
- 6) The Bank reserves the right to accept or reject any contract or / tender without assigning any reason for the same.
- 7) Please contact panel Architect **Mr. Navin M. Dhotkar, Akola. Contact No. 9422893396** for any clarification about drawing, measurement and material.


(R.R. Khade)

Regional Manager

Encl: As above


E:\RO\KHEDKAR\A&S\RANJIT\Premises\Malkapur (Akola)\Malkapur Akola_Estimate\Electrification & Data Cabling Malkapur Akola.doc

Regional Office:- "Madhumalati Building" 1st Floor, Gupte Marg, Jatharpeth, Akola. PIN: 444005

Phone No:- (0724-2491766, 2490100, Email:- ykgb.robul@gmail.com

Estimate for the Data cabling work for Vidharbha Kokan Gramin Bank, Malkapur Branch (Akola), Tq.
& Dist. Akola






















Sr, No.	Description of item.	Qty.	Unit	Rate	Amount
1	Cat 6D-Link Cable	68	mtr		
2	Cat 6 IOWith Box Single port D-link	4	No		
3	Cat 6 D-Link Patch Cord 1mtr	4	No		
4	Cat 6 D-link Patch Cord 2mtr	4	No		
5	Patch Panel D-link	1	No		
6	PVC Pipe	25	mtr		
7	Rack Fitting Charges with Anchor Bolt	1	No		
8	Patch Panel Fitting Charges with Croming	1	NO		
9	Outstation Charges (Labour)	0	lumpsum		
10	Providing earthing with 1'X1' cu plate ,coal and salt and 8 SWG Cu wire up to 10 ft.	Nos	1		
11	6Urack D-Link	1	NO		
			Total Amount Rs.		



ELECTRIC LAYOUT PLAN

PLAN SHOWING THE PROPOSED ELECTRIC LAYOUT OF VIDHARBHA
 KOKAN GRAMIN BANK, MALKAPUR BRANCH, AT MALKAPUR, AKOLA,
 TQ. AKOLA DIST. AKOLA

ARCHITECT- HAVIN M. DHOOTAR AKOLA
 OPA-ARCHITECTURAL CONSULTANCY, 13, PUSHA COMPLEX,
 SHANKAR NAGAR GORANSHIWA ROAD AKOLA,
 PH077-2426107/11, 8428532691

	FAN POINT	FAN POSITION ROOM CENTER
	CEILING LIGHT POINT	CEILING LIGHT POSITION ROOM CORNER'S 9" DISTANCE FROM BOTH WALL
	LIGHT POINT ON WALL AT 8' HT EXCEPT WHERE HT IS SHOWN IN PLAN	LIGHT POINT ON WALL AT 8' HT EXCEPT WHERE HT IS SHOWN IN PLAN
	SINGLE TUBE LIGHT MIRROR OPTIC CEILING	
	DOUBLE TUBE LIGHT MIRROR OPTIC CEILING	
	SINGLE TUBE LIGHT ON WALL AT 8' HT EXCEPT WHERE HT IS SHOWN IN PLAN	
P.P.	POWER PLUG	3/20 SUPPLY
	SWITCHES REGULATOR 5 AMP PLUG POINT AT 4'6" HT WITH NIGHT LAMP IN BOTTOM IN BED ROOM ONLY	
	SWITCH AT 4'6" EXCEPT WHERE HT IS SHOWN IN PLAN (DISTRIBUTION BOX)	
	15 AMP PLUG WITH SWITCH	
	15 AMP PLUG ONLY AT 7' HT	
	5 AMP PLUG WITH SWITCH EXCEPT WHERE SWITCH IS SHOWN IN PLAN	
	T.V POINT	
	BELL SWITCH	
	BELL AT 8' HT	
	TELEPHONE POINT	
	A.C POINT OR POINT FOR UP LIFT OF CAR	
	POINT FOR FALSE CEILING LIGHTING AT CEILING CORNER	
	EX FAN	
	CAMERA (CLOSE CIRCUIT CAMERA)	
	SPEAKER	
	ALARM	
<small>NOTES AND FITTINGS WITH E.L.C.B. WIRE GAUGE ACCORDING TO I.S. STANDARDS AND STANDARDS FOR ALL JOINTS IN CONDUIT SHALL BE TO BE COMPLETED AS PER APPROPRIATE S.I. FROM WHICH FITTING IS TO BE TAKEN. ALL FITTINGS SHALL BE WALL CENTER AS PER ARCHITECTURAL DRS. EXCEPT WHERE FITTING ARRANGEMENT ALL S.I. DATA SHALL BE TO BE TAKEN FROM THE WORKING.</small>		ARCHITECT NAVIN M. DHOTIAR AKOLA PH-2459407(O) 2439739(F) MOBILE-9422893398
<small>NOTE: READ THE DRS AS PER THE ELECTRICAL SYMBOLS PROVIDED</small>		

